

Logiciel de Débit

Échelle 1/200000

du 12/1/1971

Sault les Rethel, le 23 Janvier 1971.

Niveau statique 0.77m Profondeur du puits de la Margelle = 4.20 m

<u>Heures</u>	<u>Niveau</u>	<u>Débit</u>
30"	0.81	5,2 m <sup>3</sup> h
1'	0.81	
1'30	0.81	
2'	0/80	
2'30	0.80	
3'	0.80	
3'30	0.80	
4'	0.80	
4'30	0.80	
5'	0.80	
10'	0.80	
15'	0.80	
20'	0.80	
25'	0.80	
1'00	0.83	15,30 m <sup>3</sup> h
1'30	0.87	
2'	0.90	
2'30	0.92	
3'	0.93	
4'	0.95	
4'30	0.98	
5'	0.99	
10'	1.06	
15'	1.07	
20'	1.07	
25'	1.07,5	
30'	1.04	
40'	1.04	
45'	1.04	
50'	1.04	
55h	1.04	
60'	1.04	
75'	1.04	
90'	1.04	
3h	1.04	
3h 1'	1.21	31 m <sup>3</sup> h
1'30	1.40	
2'	1.59	
2'30	1.71	
3'	1.82	
3'30	1.95	
4'	2.02	
4'30	2.08	
5'	2.15	
10'	2.19	

Heure	Niveau	Débit
15'	2.22	
20'	2.30	
25'	2.37	
30'	2.37	
40'	2.37	
45'	2.37	
50'	2.37	
55'	2.37	
60'	2.37	
80'	2.38	
80'	2.39	
90'	2.39	
4 h.	2.39	
5 h.	2.37	
1'	2.40	
1'30	2.50	42;08 m3h
2'	2.54	
2'30	2.58	
3'	2.61	
3'30	2.63	
4'	2.65	
4'30	2.66	
5'	2.67	
10'	2.66	
20'	2.64	
30'	2.62	
40'	2.60	
50'	2.60	
60'	2.59	
15'	2.58	
30'	2.57	
45'	2.56	
60'	2.56	
7h.	2.65	
8h	2.68	
9h	2.00	
10h	2.00	
12h	2.01	
13h	2.01	
14h	2.02	
15h	2.03	
16h	2.04	
17h	2.04	
18h	2.04	
19h	2.04	
20h	2.04	
21h	2.04	
22h	2.04	
23h	2.08	
24h	2.10	
25h	2.10	
26h.	2.13	
27h	2.13	
28h	2.12	
		Changement de débit causé par les grenouilles abondantes dans le puits Démontage pompe plusieurs fois.

Heure	Niveau	Débit
29h.	2.13	
30h.	de la 29è heure à la 31è essai tous les 1/4 d'heure	
15'	2.88	50m3h
30'	2.88	
45'	2.87	
60'	2.85	
15'	2.85	
30'	2.85	
45'	2.85	
00'	2.85	
30'	2.35	
1'	1.95	
1130	1.65	
2'	1.54	
2130	1.40	
3'	1.30	
3130	1.20	
4'	1.10	
4130	1.00	
5'	0.90	
7'	0.85	
8'	0.83	
9'	0.90	
10'	0.78	
11'	0.75,5	
12'	0.77	