

ENTREPRISE YVES Cissé



Drainage - Forage - Terrassement

72120 ÉVAILLÉ

Forage : 46,33

Tél. : 43 35 13 09

Pompe : 43,66

ESSAI DE POMPAGE : M. Gange

NS/Repère : 28,25 m

Hauteur rep/sol : 930 m

NS/sol : 24,95 :

avant acidification

Date	heure	temps mn	niveau m	rabt m	débit m³/h	OBSERVATIONS
8 Mars.	14h10	0	28,25 m	0	18,43	eau blanche.
		5	29,70 m	1,45		
		10	31 m	2,75		
		15	32,40	3,85		
		20	32,75	4,5		
		25	33,33	5,08		
	15h14	0	33,33	5,08	17,20 m³	eau claire
		5	33,88	5,57		
		10	34,21	5,96		
		15	34,55	6,35		
		20	34,80	6,79		
		25	35,04	6,99		
		30	35,24	7,19		
		35	35,44	7,36		
		40	35,64	7,52		
		45	35,77	7,67		
		50	35,92	7,79		
		55	36,04	7,92		
		1h05	36,28	8,03		
		1h10	36,38	8,13		
		1h15	36,48	8,33		
		1h20	36,58	8,43		
		1h25	36,67	8,52		
		1h30	36,76	8,61		

N° GRANGE

Date	Heure	temps mn	niveau m	rabt m	débit m ³ /h	OBSERVATIONS
8 Mars	16h52	18h35	36,84	9,59	17,20	eau claire
		18h40	36,92	9,67		
		18h45	37,00	9,75		
		18h50	37,07	9,82		
		18h55	37,14	9,89		
		19h00	37,21	9,96		
		19h05	37,28	10,02		
		19h10	37,33	10,08		
		19h15	37,39	10,14		
		19h20	37,45	10,20		
		19h25	37,51	10,26		
		0	40			
		5	35,90			
		10	36,75			
		15	38,95			

Remarque

Percente auvide à 160

