

## POMPAGE EN CONTINU DE 24 HEURES

## DOSSIER :

EARL SIMON DIT ROY  
10170 Droupt Sainte Marie

## DATE :

du 28 au 29.03.19

**FORAGE : sonde AK 288**

**PIEZO : sonde BH 450**

**SOURCE 1 : sonde BH 463**

**SOURCE 2 : sonde BH 438**

8H 30	POMPAGE EN CONTINU					
	FORAGE		PIEZO		SOURCE 1	SOURCE 2
Temps	ND en m	DEBIT m <sup>3</sup> /h	ND en m		ND en m	ND en m
0,00s	4,515		4,325		0,24+	0,28
0,30mn						
1mn						
1,30mn	11,78-	83,00				
2mn						
2,30mn	11,71+	86,70				
3mn	11,775					
3,30mn	11,815	87,15				
4mn	11,80					
4,30mn	11,82+	86,90				
5mn	11,79-					
6mn	11,81					
7mn	11,73	86,80				
8mn	11,70-					
9mn	11,69					
10mn	11,68+	86,60				
12mn	11,68+	86,40	4,46+			
14mn	11,69-					
16mn	11,72-	86,51				
18mn	11,76					
20mn	11,76+					
25mn	11,78					
30mn	11,785	87,70	4,50+			
35mn	11,80					
40mn	11,79		4,52			
45mn	11,79-					
50mn	11,80	86,55	4,52+			
55mn						
1h 00	11,80+	86,32	4,53			
1h 15	11,84	86,51	4,55-			
1h 30	11,85	86,26	4,55+			0,28
2h 00						
5h 00						
7h 00	11,30	84,02	4,60-			
12h 00	11,33	84,46	4,59			0,27
16h 00						
18h 00						
20h 00						
24h 00	11,21	84,20	4,58		0,24	0,27