

BSS003LQSW

BOURGEOIS FORAGE
10700 CHAPELLE VALLON

POMPAGE PAR PALIERS

DOSSIER :
 EARL DE LA GRANGE AUX CHAMPS

Date :
 le 02.08.19

	PALIER 1					
	FORAGE POMPAGE		PIEZO			
Temps	ND en m	DEBIT m³/h	ND en m	DEBIT m³/h	ND en m	DEBIT m³/h
10h 11						
0,00s	6,54	25,00	6,35			
0,30mn						
1mn						
1,30mn	6,99	25,00				
2mn	6,94					
2,30mn	6,94					
3mn	6,92					
3,30mn	6,91					
4mn	7,04	26,03				
4,30mn	7,08					
5mn	7,08					
6mn	7,08+					
7mn	7,08+					
8mn	7,08+					
9mn	7,08+					
10mn	7,08+	25,39	6,36+			
12mn	7,08+					
14mn	7,08+					
16mn	7,08+		6,36+			
18mn	7,08+					
20mn	7,09		6,37			
25mn	7,09+					
30mn	7,09+	25,38	6,37+			
35mn	7,10					
40mn	7,10	25,40	6,38			
45mn	7,10					
50mn	7,11	25,42	6,38+			
55mn	7,11+					
1h 00	7,11+	25,42	6,38+			

BSS003LQSW

BOURGEOIS FORAGE
10700 CHAPELLE VALLON

POMPAGE PAR PALIERS

DOSSIER :
EARL DE LA GRANGE AUX CHAMPS

Date :
le 02.08.19

	PALIER 2					
	FORAGE POMPAGE		PIEZO			
Temps	ND en m	DEBIT m³/h	ND en m	DEBIT m³/h	ND en m	DEBIT m³/h
11h 11						
0,00s	7,11+	23,42	6,35+			
0,30mn						
1mn	7,94	50,34				
1,30mn	7,9					
2mn	7,89					
2,30mn	7,89-					
3mn	7,89-					
3,30mn	7,89+					
4mn	7,89+					
4,30mn	7,89+					
5mn	7,90	50,05	6,40			
6mn	7,90					
7mn	7,90					
8mn	7,90+					
9mn	7,90+					
10mn	7,90+	48,70	6,40+			
12mn	7,91					
14mn						
16mn						
18mn						
20mn	7,91+	48,30	6,41			
25mn	7,92					
30mn	7,92+	48,22	6,41+			
35mn	7,93					
40mn	7,93+	48,12	6,41+			
45mn	7,94					
50mn	7,94+	48,10	6,42+			
55mn	7,95					
1h 00	7,95+	48,12	6,43			

BSS003LQSW

BOURGEOIS FORAGE
10700 CHAPELLE VALLON

POMPAGE PAR PALIERS

DOSSIER :
EARL DE LA GRANGE AUX CHAMPS

Date :
le 02.08.19

	PALIER 3					
	FORAGE POMPAGE		PIEZO			
Temps	ND en m	DEBIT m³/h	ND en m	DEBIT m³/h	ND en m	DEBIT m³/h
12h 11						
0,00s	7,95+	48,12	6,43			
0,30mn	9,04					
1mn	9,25					
1,30mn	9,28+					
2mn	9,27					
2,30mn	9,27-					
3mn	9,25					
3,30mn	9,26+					
4mn	9,27					
4,30mn	9,27+					
5mn	9,27+	73,90	6,44+			
6mn	9,29+					
7mn	9,30					
8mn	9,30					
9mn	9,30					
10mn	9,30+	73,72	6,45			
12mn	9,32					
14mn	9,32-					
16mn	9,31					
18mn	9,31+					
20mn	9,33	73,72	6,45+			
25mn	9,34					
30mn	9,35	73,57	6,47			
35mn	9,35+					
40mn	9,36+	73,50	6,47+			
45mn	9,37					
50mn	9,37+	73,50	6,47+			
55mn	9,37					
1h 00	9,37	73,35	6,47+			

BSS003LQSW

BOURGEOIS FORAGE
10700 CHAPELLE VALLON

POMPAGE PAR PALIERS

DOSSIER :
EARL DE LA GRANGE AUX CHAMPS

Date :
le 02.08.19

	PALIER 4					
	FORAGE POMPAGE		PIEZO			
Temps	ND en m	DEBIT m³/h	ND en m	DEBIT m³/h	ND en m	DEBIT m³/h
13h 11						
0,00s	9,37	73,35	6,47+			
0,30mn	11,08					
1mn	11,49					
1,30mn	11,6					
2mn	11,66					
2,30mn	11,73					
3mn	11,77					
3,30mn	11,78					
4mn	11,80					
4,30mn	11,82					
5mn	11,83	99,55	6,50			
6mn	11,86					
7mn	11,87					
8mn	11,87					
9mn	11,88					
10mn	11,89	99,60	6,50			
12mn	11,92					
14mn	11,95					
16mn	11,97					
18mn	11,97+					
20mn	12,00	99,55	6,50+			
25mn	12,00					
30mn	12,03	99,20	6,51			
35mn	12,05					
40mn	12,05					
45mn						
50mn						
55mn						
1h 00						

BSS003LQSW

BOURGEOIS FORAGE
10700 CHAPELLE VALLON

POMPAGE EN CONTINU DE 24 HEURES

DOSSIER :
EARL DE LA GRANGE AUX CHAMPS

DATE :
du 03 au 04.08.19

POMPAGE EN CONTINU						
	FORAGE POMPAGE		PIEZO		RIVIERE	
Temps	ND en m	DEBIT m ³ /h	ND en m	DEBIT m ³ /h	ND en m	DEBIT m ³ /h
7h 36						
0,00s	6,55		6,40		à sec	
0,30mn						
1mn	8,93	75,62			voir	photos
1,30mn	8,89					
2mn	8,88-					
2,30mn	8,89-					
3mn	8,91					
3,30mn	8,91+					
4mn	8,91+	75,29				
4,30mn	8,92-					
5mn	8,92+					
6mn	8,93+					
7mn	8,96					
8mn	8,97-					
9mn						
10mn	9,01-	75,62				
12mn	9,02					
14mn	9,05					
16mn	9,06+					
18mn	9,07	75,53				
20mn	9,08		6,46			
25mn	9,11-					
30mn	9,11	75,37	6,48+			
35mn	9,125					
40mn	9,14	75,39	6,495			
45mn	9,15+					
50mn	9,16+					
55mn	9,18					
1h 00	9,19		6,52			
1h 15						
1h 30						
1h 45						
2h 00	9,24	75,26	6,56			
2h 30						
3h 00						
3h 30						
4h 00						
4h 30						
5h 00						
8h 00	9,51+	75,45	6,675			
9h 25						
24h 00	9,620	75,28	6,81			