

Date	Heure	Temps	Débit	Sonde	Niveau/sol	Rabatt	Observation
02/08/2010	10:20	3h10		27.60	26.80	11.15	compteur :75712
	10:21	3h11	0.00	20.02	19.22	3.57	
	10:22	3h12		18.11	17.31	1.66	
	10:23	3h13		17.81	17.01	1.36	
	10:24	3h14		17.70	16.90	1.25	
	10:26	3h16		17.57	16.77	1.12	
	10:28	3h18		17.51	16.71	1.06	
	10:30	3h20		17.46	16.66	1.01	
	10:35	3h25		17.38	16.58	0.93	
	10:40	3h30		17.34	16.54	0.89	
	10:45	3h35		17.29	16.49	0.84	
	10:50	3h40	42.50	24.08	23.28	7.63	compteur :75712 longue durée
	10:55	3h45		24.26	23.46	7.81	
	11:00	3h50		23.35	22.55	6.90	
	11:15	4h05		24.46	23.66	8.01	
	11:30	4h20		24.52	23.72	8.07	arrêt du pompage (panne groupe du 31 juillet 20h15 au 1er août 12h25)
	11:45	4h35		24.56	23.76	8.11	
	12:00	4h50		24.54	23.74	8.09	
	06:30	71h20		23.69	22.89	7.24	
	07:00	71h50		23.68	22.88	7.23	compteur :77917 arrêt longue durée
	10:45	75h35	0.00	17.00	16.20	0.55	
	10:50	75h40	19.50	15.65	14.85	-0.80	essai de réinjection
	10:55	75h45		15.30	14.50	-1.15	
	11:00	75h50		15.24	14.44	-1.21	
	11:05	75h55		15.23	14.43	-1.22	
	11:10	76h00		15.20	14.40	-1.25	
	11:15	76h05	36.46	10.34	9.54	-6.11	
	11:20	76h10		7.82	7.02	-8.63	
	11:30	76h20		7.31	6.51	-9.14	
	11:35	76h25		6.80	6.00	-9.65	
	11:40	76h30	36.80	6.55	5.75	-9.90	
	11:45	76h35		6.28	5.48	-10.17	
	11:50	76h40		6.20	5.40	-10.25	
	11:55	76h45		6.11	5.31	-10.34	
	12:00	76h50		6.01	5.21	-10.44	
	12:05	76h55	33.80	7.13	6.33	-9.32	
	12:10	77h00		7.30	6.50	-9.15	
	12:20	77h10	33.75	7.34	6.54	-9.11	
	12:30	77h20		7.29	6.49	-9.16	
03/08/2010	06:35	95h25	35.00	6.45	5.65	-10.00	
	06:45	95h35		6.46	5.66	-9.99	
	07:05	95h55		6.67	5.87	-9.78	
	07:30	96h20		6.61	5.81	-9.84	