

BOURGEOIS FORAGE
10700 CHAPELLE VALLON

POMPAGE PAR PALIER

DOSSIER :
 SCEA TISSUT
 SCEA SAINT AVENTIN

DATE :
 le 23.09.2020

10h 07	PALIER 3					
	FORAGE					
	ND en m	DEBIT m ³ /h	ND en m	DEBIT m ³ /h	ND en m	DEBIT m ³ /h
0,00s	21,66+					
0,30mn						
1mn	23,650	104,30				
1,30mn	23,930	102,90				
2mn						
2,30mn	24,410	106,40				
3mn	24,570	105,60				
3,30mn	24,650	106,40				
4mn	24,700	105,30				
4,30mn	24,72+	104,70				
5mn	24,730	104,60				
6mn	24,820	105,60				
7mn	24,910	105,90				
8mn	24,980	105,30				
9mn	25,040	105,30				
10mn	25,070	105,10				
12mn	25,070	104,90				
14mn	25,170	105,60				
16mn	25,23+	105,90				
18mn	25,280	105,50				
20mn	25,300	105,30				
25mn	25,23+	105,40				
30mn	25,480	105,10				
35mn	25,660	105,60				
40mn	25,720	105,60				
45mn	25,760	105,70				
50mn	25,910	105,10				
55mn	25,900	105,20				
1h 00	25,980	105,30				