

BOURGEOIS FORAGE
10700 CHAPELLE VALLON

POMPAGE PAR PALIER

DOSSIER :
 SCEA TISSUT
 SCEA SAINT AVENTIN

DATE :
 le 23.09.2020

11h 07	PALIER 4					
	FORAGE					
	ND en m	DEBIT m ³ /h	ND en m	DEBIT m ³ /h	ND en m	DEBIT m ³ /h
0,00s	25,980					
0,30mn						
1mn	29,250	141,50				
1,30mn						
2mn	30,900	140,20				
2,30mn						
3mn						
3,30mn	32,650	132,80				
4mn	32,950	136,10				
4,30mn	33,250	133,70				
5mn	33,680	136,90				
6mn	33,800	134,50				
7mn	33,900	134,80				
8mn	33,950	133,40				
9mn						
10mn	34,280	135,20				
12mn	34,310	134,90				
14mn	34,350	135,10				
16mn						
18mn	34,780	132,80				
20mn	34,810	132,20				
25mn	34,980	133,50				
30mn		133,20				
35mn	35,600	133,50				
40mn	35,050	131,60				
45mn	35,900	131,30				
50mn	35,250	131,40				
55mn	35,800	130,50				
1h 00	36,050					