

Date	Heure	Temps	Débit	Sonde	Niveau/sol	Rabatt.	Observation
	09:08	1h08		9.57	9.57	0.02	
	09:10	1h10		9.57	9.57	0.02	
	09:12	1h12		9.57	9.57	0.02	
	09:14	1h14		9.57	9.57	0.02	
	09:16	1h16		9.57	9.57	0.02	
	09:18	1h18		9.57	9.57	0.02	
	09:20	1h20		9.57	9.57	0.02	
	09:25	1h25		9.57	9.57	0.02	
	09:30	1h30		9.57	9.57	0.02	
	09:40	1h40		9.57	9.57	0.02	
	09:50	1h50		9.57	9.57	0.02	
	10:00	2h00		9.57	9.57	0.02	
	10:01	2h01	25.00	9.58	9.58	0.03	Aug/débit
	10:02	2h02		9.58	9.58	0.03	Palier n°3
	10:03	2h03		9.59	9.59	0.04	
	10:04	2h04		9.59	9.59	0.04	
	10:05	2h05		9.60	9.60	0.05	
	10:06	2h06		9.60	9.60	0.05	
	10:07	2h07		9.61	9.61	0.06	
	10:08	2h08		9.61	9.61	0.06	
	10:10	2h10		9.61	9.61	0.06	
	10:12	2h12		9.61	9.61	0.06	
	10:14	2h14		9.61	9.61	0.06	
	10:16	2h16		9.61	9.61	0.06	
	10:18	2h18		9.61	9.61	0.06	
	10:20	2h20		9.61	9.61	0.06	
	10:25	2h25		9.61	9.61	0.06	
	10:30	2h30		9.61	9.61	0.06	
	10:40	2h40		9.61	9.61	0.06	
	10:50	2h50		9.61	9.61	0.06	
	11:00	3h00		9.61	9.61	0.06	Aug/débit
	11:01	3h01	44.54	9.62	9.62	0.07	Palier n°4
	11:02	3h02		9.63	9.63	0.08	
	11:03	3h03		9.63	9.63	0.08	
	11:04	3h04		9.63	9.63	0.08	
	11:05	3h05		9.63	9.63	0.08	
	11:06	3h06		9.63	9.63	0.08	
	11:07	3h07		9.63	9.63	0.08	
	11:08	3h08		9.63	9.63	0.08	
	11:10	3h10		9.63	9.63	0.08	
	11:12	3h12		9.63	9.63	0.08	
	11:14	3h14		9.63	9.63	0.08	
	11:16	3h16		9.63	9.63	0.08	
	11:18	3h18		9.63	9.63	0.08	
	11:20	3h20		9.63	9.63	0.08	
	11:25	3h25		9.63	9.63	0.08	
	11:30	3h30		9.63	9.63	0.08	
	11:40	3h40		9.63	9.63	0.08	
	11:50	3h50		9.63	9.63	0.08	
	12:00	4h00		9.63	9.63	0.08	Arrêt pompe
	12:01	4h01	0.00	9.58	9.58	0.03	Remontée
	12:02	4h02		9.58	9.58	0.03	